## **Plumbing Pressure Test Memorandum**

Issued by: (Plumber)	Registration Number:
Company Name:	
Company Address:	
Company Contact Details: Ph:	Mb: Fx:
То:	Hamilton City Council Hauraki District Council Matamata-Piako District Council Otorohanga District Council Thames-Coromandel District Council Waikato District Council Waipa District Council Waitomo District Council
Building Consent Number:	
Building Owner:	
Project Address:	
Description of Building Work:	Completion of a pressure test on the plumbing system
Scope of work covered by statement:	We certify that the system was tested to 1500kpa for a period of 30 minutes. This test was conducted in accordance with manufacturer recommendations and complies with the pressure testing provisions of the New Zealand Building Code and Approved Solution G12 AS1 and AS/NZS3500.1.2 as appropriate.
	☐ I understand that this Statement, if accepted, may be relied upon for the purpose of establishing compliance with the Building Code and Building Consent.
Signed by: (Plumber)	Date:

The Waikato Building Consent Group Producer Statement Author register is held by the Waikato Building Consent Group, Email: info@buildwaikato.co.nz For information on the Waikato Building Consent Group visit the <a href="Build Waikato">Build Waikato</a> website.